

## ADDENDUM NO. 1

City Project No.: M-014-M15-34, J7821

“Sanitary Capacity Improvements to the Homestead Sewer”

ISSUED: September 25, 2015

BIDS OPENED AT: September 30, 2015

YOUR BID MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM.

The following additions, corrections, or modifications are hereby made a part of the Contract Documents for the above referenced project.


The Proposal & Plan shall be revised as follows:

### PROPOSAL

#### 1. Revise S – 40.1 Furnish & Install ( )” Plug

Add the following:

Each plug installed on the existing water that will remain active will require a corporation to be installed to remove air from the system. The existing watermain that will be abandoned will require a plug to be installed. The installation of the plug on the abandoned line and the corporation will be incidental to the pay item Furnish & Install ( )” Plug.



Timothy A. Hruska, PE  
This addendum is 1 page.